


Horizontal cable to ground rod tee joint - CR2

A	B	So			
12.7	16	D	#090	HCD	MDCR212.716
12.7	25	D	#090	HCD	MDCR212.725
12.7	35	D	#090	HCD	MDCR212.735
12.7	50	D	#090	HCD	MDCR212.750
12.7	70	D	#090	HCD	MDCR212.770
12.7	95	D	#115	HCD	MDCR212.795
12.7	8 dia	D	#065	HCD	MDCR212.78S
12.7	10 dia	D	#090	HCD	MDCR212.710S
14.2	16	D	#090	HCD	MDCR214.216
14.2	25	D	#090	HCD	MDCR214.225
14.2	35	D	#090	HCD	MDCR214.235
14.2	50	D	#090	HCD	MDCR214.250
14.2	70	D	#115	HCD	MDCR214.270
14.2	95	D	#115	HCD	MDCR214.295
14.2	120	D	#150	HCD	MDCR214.2120
14.2	150	D	#200	HCD	MDCR214.2150
14.2	185	D	#200	HCD	MDCR214.2185
14.2	240	D	#250	HCD	MDCR214.2240
14.2	8 dia	D	#090	HCD	MDCR214.28S
14.2	10 dia	D	#115	HCD	MDCR214.210S
17.2	16	D	#090	HCD	MDCR217.216
17.2	25	D	#090	HCD	MDCR217.225
17.2	35	D	#090	HCD	MDCR217.235
17.2	50	D	#115	HCD	MDCR217.250
17.2	70	D	#115	HCD	MDCR217.270
17.2	95	D	#115	HCD	MDCR217.295
17.2	120	D	#150	HCD	MDCR217.2120
17.2	150	D	#200	HCD	MDCR217.2150
17.2	185	D	#200	HCD	MDCR217.2185
17.2	240	D	#250	HCD	MDCR217.2240
17.2	300	E	2 x #150	HCE	MECR217.2300
16	16	D	#90	HCD	MDCR21616
16	25	D	#90	HCD	MDCR21625
16	35	D	#90	HCD	MDCR21635
16	50	D	#90	HCD	MDCR21650
16	70	D	#115	HCD	MDCR21670
16	95	D	#115	HCD	MDCR21695
16	120	D	#150	HCD	MDCR216120
16	150	D	#200	HCD	MDCR216150
16	185	D	#200	HCD	MDCR216185
16	240	D	#250	HCD	MDCR216240
16	300	D	#250	HCD	MDCR216300
16	400	E	2 x #200	HCE	MECR216400
20	16	D	#90	HCD	MDCR22016
20	25	D	#90	HCD	MDCR22025
20	35	D	#90	HCD	MDCR22035
20	50	D	#150	HCD	MDCR22050
20	70	D	#150	HCD	MDCR22070
20	95	D	#115	HCD	MDCR22095
20	120	D	#200	HCD	MDCR220120
20	240	D	#250	HCD	MDCR220240
20	300	D	2 x #150	HCD	MDCR220300
20	400	E	2 x #200	HCE	MECR220400



A 12.7, 14.2 and 17.2 = copperbond
16 and 20 = solid copper/steel

B 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300 and 400
= stranded cable (mm²)
8 dia and 10 dia = solid copper/steel